



City of La Salle Building Codes

2003 IBC – International Building Code

2003 IRC – International Residential Code

Amendments

1. Section R502.11.1 Design. Add the following: “Engineered trusses for flooring which utilize metal for the truss portion of the floor joist shall not be allowed.”

2003 IFC – International Fire Code

Amendments

1. **Section 3204.3.1.1** (geographic limits in which the storage of flammable cryogenic fluids in stationary containers is prohibited): “All areas other than those zoned M-1 or M-2 within the corporate limits of the City of LaSalle.”
2. **Section 3404.2.9.5.1** (geographic limits in which the storage of Class I and Class II liquids in above-ground tanks outside of buildings is prohibited): “All areas with residential zoning (areas zoned R-1, R-2, R-3 and R-4) within the corporate limits of the City of LaSalle.”
3. **Section 3406.2.4.4** (Geographic limits in which the storage of Class I and Class II liquids in above-ground tanks is prohibited): “All areas with residential zoning (areas zoned R-1, R-2, R-3 and R-4) within the corporate limits of the City of LaSalle.”
4. **Section 3804.2** (geographic limits in which the storage of liquid petroleum gas is restricted for the protection of heavily populated or congested areas): “All areas with residential zoning (areas zoned R-1, R-2, R-3 and R-4) within the corporate limits of the City of LaSalle.”

(Ord. 1793, passed 3-31-2003)

2003 IFGC – International Fuel Gas Code

2003 IPMC – International Property Maintenance Code

Amendments

1. **Section 302.4** Insert “six (6) inches.” (Maximum Grass and Weed Height)
2. **Section 304.14** Insert “May 1 to September 30.” (Insect screens required)
3. **Section 602.3** Insert “October 1 to May 31.” (Minimum heat supply of 68 deg.)
4. **Section 602.4** Insert “October 1 to May 31.” (Minimum heat in working spaces of 65 degrees)

5. **Section 604.2** Add the following: “If the meter is removed at any time, the service shall be upgraded to a minimum of 100 amperes.”
6. **Section 605.2** Delete the last sentence and add the following: “All bathroom receptacles and receptacles serving the kitchen counter shall be of the ground fault circuit interrupter type.”
7. **Section 702(F)**, means of egress, the following addition is made thereto: “It shall be unlawful in any place or in any manner to block, impede, hamper, occupy or obstruct the immediate means of egress from any fire escape which provides any means of egress, or emergency means of egress or rescue from any building or structure within the City of LaSalle.” That the penalty for violating this division (14) shall be as provided within division (B)(6) of this section.

2003 IMC – International Mechanical Code

2002 NEC – National Electric Code

Amendments

1. **Article 310.2 Conductors:** Delete the text of Article 310.2 (B) and substitute the following: “Conductor Material. Conductors in this article shall be of copper. Aluminum is only approved for use by the local electric utility for service installations.”
2. **Article 320 - Armored Cable (BX):** This may only be used as an extension to an existing system of a residence where it is impossible to use conduit. This method will not be used in a basement; except for a short piece to connect to junction box
3. **Article 322 Flat Cable Assemblies:** Type FC and Article 324: - Flat conductor Cable: Type FCC - Can be used only for the repair of existing systems.
4. **Article 334 - Nonmetallic-Sheathed Cable:** This method will only be allowed in 1 or 2-family dwellings and shall only be allowed in floors located above grade. In no case will this method be allowed in a basement or any other story located below grade.
5. **Article 338 - Service-Entrance Cable:** Use of this method is not permitted unless approved by the Building Inspector.
6. **Article 340 - Underground Feeder and Branch Circuit Cable:** Paragraph 340-10(4) is not acceptable. Type OF Cable shall not be used in any basement or other story located below grade.
7. **Article 362 - Electrical Nonmetallic Tubing - Type ENT:** Use of this method is only permitted in concealed locations in all uses.

2012 IECC – International Energy Conservation Code

State of Illinois Plumbing Code