

## Annual Drinking Water Quality Report for LA SALLE IL0990300 for the period of January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

**Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.**

The source of drinking water used by LA SALLE is Ground Water

For more information regarding this report contact: Christopher Perra at 815-252-9637 or the City of La Salle at 815-223-3755

### Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The drinking water supplier is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk.

Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standard Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact at Christopher Perra at 815-252-9637.

Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Source Water Name	Type of Water	Report Status	Location
WELL 10 (01112)	GW		
WELL 11 (01551) SOUTH OF WELL 9	GW		

WELL 12 (01762)	GW	180' W OF OLD ILLINOIS CENTRAL RAILROAD & 300'N OF IL RIVER
WELL 13 (02113)	GW	
WELL 6 (11467)	GW	
WELL 9 (00815)	GW	

**Source Water Assessment**

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 815-252-9637. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: LA SALLE To determine LaSalle's susceptibility to groundwater contamination, a Well Site Survey, published in 1990 by the Illinois EPA, was reviewed. Based on the information contained in this document, five potential sources of groundwater contamination are present that could pose a hazard to groundwater pumped by the LaSalle community water supply wells. These include a ready mix/cement, two machine shops/sheds, an inactive auto repair, and an inactive water treatment plant. The Illinois EPA has determined that LaSalle Wells #4, #6, #8, #9, and #10 are susceptible to contamination. The basis for this susceptibility determination is the location of non-point sources related to agricultural land use and the location of potential sources within the recharge area of the wells. In 2008, LaSalle received a Non-Compliance Advisory (NCA) for bacteriological detections in Wells #4, #6 and #8. Several test holes in the wellfield were found to be improperly abandoned, allowing surface water to potentially contaminate the LaSalle CWS wells. These test holes were subsequently sealed in accordance with Illinois Dept. of Public Health well sealing regulations. While the NCA has been resolved at this time, monitoring data is continually being tracked in regards to all active potable wells at the facility, and further deficiencies would result in additional enforcement.

**2025 Regulated Contaminants Detected**

**Lead and Copper**

Definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Copper Range: <10 ppb to 1,380 ppb

Lead Range: <5 ppb to 76.4 ppb

To obtain a copy of the system's lead tap sampling data: The lead sampling data is available on Illinois EPA's Drinking Water Watch <https://water.epa.state.il.us/dww/index.jsp>

To navigate the DWW website: search for your PWS, click on Chem/Rad Samples/Results by Analyte under Links on the left hand side, and click on either Lead or Copper, Free to review the results.

Our Community Water Supply has developed a service line material inventory.

To obtain a copy of the system's service line inventory: Christopher Perra at 815-252-9637

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2025	1.3	1.3	0.921	1	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits.
Lead	2025	0	15	9.03	1	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

**Water Quality Test Results**

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

mrem: millirems per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

**Regulated Contaminants**

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2025	1.5	0.99 - 2	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2025	47	25.08 - 51.9	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2025	69	21 - 122	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	02/08/2023	0.1	0.1 - 0.1	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	02/08/2023	0.651	0.651 - 0.651	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2025	0.358	0.194 - 0.358	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Selenium	02/08/2023	1.6	1.6 - 1.6	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
Sodium	02/08/2023	66	66 - 66			ppb	N	Erosion from naturally occurring deposits. Used in water softener regeneration.
<b>Radioactive Contaminants</b>	<b>Collection Date</b>	<b>Highest Level Detected</b>	<b>Range of Levels Detected</b>	<b>MCLG</b>	<b>MCL</b>	<b>Units</b>	<b>Violation</b>	<b>Likely Source of Contamination</b>
Combined Radium 226/228	01/06/2021	0.837	0.837 - 0.837	0	5	pCi/L	N	Erosion of natural deposits.

*Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.*

*Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.*

**Violations Table**

**Haloacetic Acids (HAA5)**

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

<b>Violation Type</b>	<b>Violation Begin</b>	<b>Violation End</b>	<b>Violation Explanation</b>
MONITORING, ROUTINE (DBP), MAJOR	10/01/2025	12/31/2025	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Due to a lab equipment issue, HAA5 needed to be resampled at S2HH1 and S2HT1 locations. These resamples were completed and submitted to the EPA in March of 2026. A public notice for the above violation is included with this CCR.

## Monitoring Violations Annual Notice Template

### IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for [IL0990300 – LA SALLE]

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During [10/01/2025-12/31/2025] we [did not complete all monitoring or testing] for [contaminant(s)] and therefore cannot be sure of the quality of our drinking water during that time.*

#### What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for [these contaminants], how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
[HAA5]	[Quarterly]	[0]	[10/1/2025-12/31/2025]	March of 2026
[HAA5]	[Quarterly]	[0]	[10/1/2025-12/31/2025]	March of 2026

#### What happened? What is being done?

We collected samples and tested for HAA5 at S2HH1 during the required sampling period, but due to a lab equipment issue HAA5 needed to be resampled. The resample was completed in March of 2026 with samples satisfactory to EPA guidelines.

We collected samples and tested for HAA5 at S2HT1 during the required sampling period, but due to a lab equipment issue HAA5 needed to be resampled. The resample was completed in March of 2026 with samples satisfactory to EPA guidelines.

No other action is needed.

For more information, please contact Chris Perra at 815-252-9637 or 2323 4<sup>th</sup> St, Peru, IL 61354.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by [LA SALLE]

Water System  
ID#

IL0990300

Date distributed

with 2025 CCR

# Special Notice for Availability of Unregulated Contaminant Monitoring Data

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Availability of Monitoring Data for Unregulated Contaminants for [CITY OF LASALLE]

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by EPA. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact [Chris Perra] at [815-252-9637] or [2323 4<sup>th</sup> Street, Peru, IL 61354].

#### UCMR5 Data

Analyte	Collection Date	Result Measure ug/L	Range of Levels Detected	Average of monitoring results	Sample Point	Sampling Event	Method
Lithium	4/7/2025	16.0	16.0 – 20.0	18.0	TP03	SE1	200.7
	10/15/2025	20.0			TP03	SE2	200.7
PFBA	4/7/2025	0.0052	0.0052 – 0.0067	0.00595	TP03	SE1	533
	10/15/2025	0.0067			TP03	SE2	533
PFBS	10/15/2025	0.0031	0.0031 – 0.0031	0.0031	TP03	SE2	533

A maximum contaminant level (MCL) for this contaminant has not been established by either state or federal regulations, nor has mandatory health effects language been set. The purpose of unregulated contaminant monitoring is to assist USEPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

This notice is being sent to you by [LaSalle]. State Water System ID#: [IL0990300](#).

Date distributed: [with 2025 CCR](#).