

CITY OF LA SALLE PUBLIC WATER SUPPLY
FOR MONTH OF MARCH 2022

DIVISION OF PUBLIC WATER SUPPLIES

RAW WATER				CHEMICALS APPLIED										FILTERS				CHEMICAL TESTS														REMARKS Use reverse side for additional remarks		
Meter Read AM	Reading (1000 gal.)	Treated (1000 gal.)	Used lbs. or Gal.	Chlorine		Fluoride		NaMnO4		Ortho Phosphate		Used lbs. or Gal.	Calc mg/l	Each day indicate total previous backwash, if backwashed at mid-day, indicate hours previous hours following.	Wash Water Used Gal.	RAW						FINISHED												
				Used lbs. or Gal.	Calc mg/l					Used lbs. or Gal.	Calc mg/l	pH	Alk. as Calc CO3 mg/l	Hard as Calc CO3 mg/l	Fe mg/l	Mn mg/l	pH	Ortho Phosphate mg/l	Hard as Calc CO3 mg/l	Fe mg/l	Mn mg/l	F mg/l	Cl res. F = Free T = Total											
a	b	c	d	e	f	g	h	i	j	k	l	m	n	o	p	q	r	s	t	u	v	w	x	y	z	aa	bb	cc	dd	ee	ff		gg	hh
1	6:00A	43518	1.5	49	3.91	19	0.27	41	0.85	16	0.63			118				42	7.22			0.11	0.295	7.6	1.16		0	0.023	0.46	2.21	1.99			
2	6:30A	1500	1.588	29	2.18	12	0.16	29	0.43	13	0.49											7.15					0.05	0.028	0.98	1.93	1.83			
3	6:00A	3088	1.675	35	2.5	13	0.16	34	0.48	9	0.32											7.25					0.01	0.021	1.08	2.14	1.81			
4	6:00A	4763	1.497	39	3.12	23	0.33	39	0.62	14	0.56											7.26					0.05	0.016	0.96	1.7	1.56			
5	6:00A	6260	1.611	33	2.45	8	0.1	35	0.52	10	0.37																							
6	6:30A	7871	1.744	53	3.64	11	0.13	34	0.46	15	0.51																0	0.011	0.97	2.46	2.18			
7	9:00A	9615	1.513	32	2.37	5	0.07	31	0.42	0.28				142				42	7.32			0.17	0.244	7.78	1.63		0	0.011	0.97	2.46	2.18			
8	6:00A	11129	1.696	48	3.30	5	0.06	44	0.62	12	0.42											7.28					0.01	0.029	0.74	1.82	1.43			
9	9:00A	12824	1.596	41	3.09	27	0.37	29	0.43	13	0.49											7.24					0	0.024	0.81	2.68	2.38			
10	7:00A	14410	1.498	41	3.28	15	0.21	37	0.59	13	0.52											7.17					0.02	0.023	1.12	1.92	1.71			
11	7:30A	15908	1.584	33	2.49	15	0.2	37	0.56	12	0.45			92				42	7.31			0.09	0.25	7.58	1.14		0.02	0.033	0.96	1.73	1.39			
12	8:30A	17492	1.575	23	2.31	12	0.16	33	0.5	11	0.41																							
13	6:00A	19667	1.512	38	3.01	10	0.14	45	0.71	11	0.43											7.33					0.01	0.02	0.98	1.63	1.46			
14	9:00A	20579	1.738	38	2.53	13	0.14	35	0.48	10	0.33											7.34					0.01	0.024	0.74	1.26	1.06			
15	8:00A	22377	1.689	50	3.54	12	0.15	29	0.41	11	0.39											7.15					0.01	0.017	0.79	2.54	2.09			
16	7:00A	24056	1.531	32	2.35	11	0.14	36	0.52	12	0.44											7.24					0.01	0.019	0.76	1.56	1.14			
17	8:00A	25697	1.666	44	3.16	12	0.15	45	0.84	10	0.35			140				42	7.28			0.14	0.256	0.759	1.53		0.01	0.019	0.76	1.56	1.14			
18	7:00A	27363	1.689	30	2.12	8	0.1	29	0.41	8	0.28											7.32					0.01	0.012	1.04	2.5	2.41			
19	6:00A	29052	1.424	49	4.12	12	0.16	30	0.5	7	0.29																							
20	8:00A	30476	1.364	37	3.21	9	0.14	33	0.57	8	0.52											7.24					0.01	0.006	0.96	1.4	1.15			
21	6:30A	31860	1.723	38	2.64	10	0.13	32	0.45	5	0.35											7.24					0	0.016	0.61	1.93	1.62			
22	6:30A	33563	1.547	39	3.02	15	0.21	45	0.7	6	0.47			118				42	7.24			0.1	0.25	7.48	1.31		0	0.016	0.61	1.93	1.62			
23	6:45A	35130	1.624	47	2.93	15	0.17	30	0.41	4	0.25											7.22					0.01	0.009	0.69	1.44	1.27			
24	6:45A	37054	1.585	32	2.47	19	0.27	33	0.51	4	0.31											7.3					0.01	0.021	0.63	2.63	2.39			
25	6:15A	38669	1.506	52	4.05	22	0.31	40	0.82	3	0.23											7.23					0.01	0.019	0.75	1.69	1.43			
26	8:00A	40145	1.847	47	3.42	16	0.21	32	0.46	3	0.21																							
27	7:00A	41792	1.393	40	3.44	18	0.28	22	0.37	2	0.17											7.25					0.01	0.017	0.66	2.99	2.98			
28	6:55A	43185	1.516	32	2.53	20	0.29	36	0.57	4	0.32			144				42	7.25			0.19	0.244	7.56	0.73		0.01	0.017	0.66	2.99	2.98			
29	6:55A	44701	1.607	35	2.61	20	0.27	35	0.52	4	0.3											7.26					0.01	0.016	0.71	1.93	1.74			
30	6:20A	46308	1.489	37	2.98	22	0.32	37	0.6	4	0.32											7.3					0	0.013	0.73	1.89	1.67			
31	6:45A	47797	1.65	31	2.35	23	0.3	34	0.49	4	0.29			73				42	7.38			0.02	0.202	7.62	1.14		0	0.016	0.74	1.44	1.67			
TOT.	0	787216	49.447	1212	91.31		6.12	1094	25.78	298	11.81	0	0	807	0	0	0	294	167	0	0	3.13	5.741	167.2	27.88	0	0	0.27	0.433	18.41	63.45	7		
MAX.	0	47797	1.824	53	4.12	27	0.37	45	1.0	42	0.63	0	0	144	0	0	0	42	7.38	0	0	0.2	0.283	7.78	1.68	0	0	0.05	0.033	1.12	2.89	2.58	0	
MIN.	0	1500	1.384	29	2.12	5	0.06	22	0.37	2	0.17	0	0	73	0	0	0	42	7.15	0	0	0.02	0.032	0.759	0.71	0	0	0	0.006	0.46	1.26	1.06	0	
AVE.	#DIV/0!	25394.065	1.5950445	39.1	3.045	14.58	0.197	34.97	0.832	9.613	0.381	average	average	118.1	average	average	average	42	7.263	average	average	0.136	0.25	7.27	1.212	average	average	0.012	0.019	0.8	2.047	1.792	39388	

*Enter Final Reading Last Month

Pre & Post Filters Post Filter Pre Filter Post Filter

POINT OF APPLICATION

METER LOCATION: Main Pump Station

2. % Fluoride Solution Fed

3. % Solution Fed

4. % Solution Fed

CHLORINE

Type of Chlorine Used:

Chlorine Gas

Calcium Hypochlorite

Sodium Hypochlorite

Chlorine Test Kit Used: Hach DPD

FLUORIDATION

Type of Fluoride Used:

Hydrofluoric Acid, 5F

Sodium Fluoride

Other

Type of Test Instrument Used: Hach SPADNS

This Agency is Authorized to require this information under Ill. Rev. Stat., 1976, Chapter 111 U.S. Section 8019. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continues, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the Forms Management Center.

I certify that the information in this report is complete and accurate to the best of my knowledge.

B.D.R. 7110543 4-6-22

Fluorinated by: (Signature) Cert or Reg Number Date

Phone: 815.233.0068 Date Monthly Check by: POC LMBS Bacterials Cert

DIVISION OF PUBLIC WATER SUPPLIES

RAW WATER				CHEMICALS APPLIED								FILTERS				CHEMICAL TESTS												REMARKS					
Meter Read AM	Reading (1000 gal)	Treated (1000 gal)	Chlorine		Fluoride		NaMnO4		Ortho Phosphate		Each day indicate total previous backwash. If backwashed at mid-day, indicate hours previous/ hours following		Wash Water Used Gal.	RAW						FINISHED													
			Used lbs. of Gal.	Calc mg/l	Used lbs. of Gal.	Calc mg/l	Used lbs. of Gal.	Calc mg/l	Used lbs. of Gal.	Calc mg/l	1	2		3	4	pH	Alk. as CaCO3 mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	pH	Ortho Phosphate mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	F mg/l	Cl res, F = free T = total						
a	b	c	e	f	g	h	i	j	k	l	m	n	o	p	q	r	s	t	u	v	w	x	y	z	aa	bb	cc		dd	ee	ff	gg	hh
1	5:40A	48575	2.18	50	2.75	24	0.24	41	0.45	55	3.03							7.3			0.06	0.24	7.63	1.16		0	0.019	0.79	2.43	2.1		Hydrant Flushing	
2	5:40A	2180	1.802	51	3.39	25	0.3	37	0.49	52	3.46							7.29			0.1	0.269	7.62	1.24		0	0.015	0.71	2.49	2.46			
3	5:30A	3592	1.873	52	3.32	24	0.27	42	0.53	56	3.71							7.28			0.09	0.268	7.65	0.91		0.01	0.017	0.68	2.29	2.11			
4	7:00A	4855	1.665	52	3.75	25	0.32	40	0.07	40	2.89																						
5	8:00A	7540	1.873	40	2.56	20	0.25	30	0.38	45	2.88																						
6	5:30A	9413	1.644	51	3.72	25	0.33	38	0.55	53	3.87	142														0.01	0.014	0.71	2.28	1.97			
7	5:55A	11057	1.78	45	3.03	23	0.28	32	0.43	46	3.1															0	0.011	0.82	2.6	2.27			
8	5:35A	12837	1.773	47	3.18	22	0.27	38	0.51	43	2.91															0.01	0.015	0.65	2.48	2.33			
9	5:40A	14610	1.539	39	3.04	23	0.25	33	0.51	39	3.04															0.01	0.016	0.78	2.33	2.22			
10	5:35A	17522	1.803	43	2.88	23	0.28	36	0.48	42	2.79															0.01	0.012	0.66	2.36	1.85			
11	6:00A	19725	1.651	42	3.05	20	0.29	31	0.45	39	2.83																						
12	5:22A	21376	1.512	50	3.97	24	0.35	34	0.54	44	3.49																						
13	5:45A	22888	1.781	56	3.77	27	0.33	40	0.54	49	3.3	167														0.01	0.022	0.75	2.7	2.67			
14	5:35A	24669	1.923	54	3.37	25	0.28	37	0.46	55	3.43															0.01	0.021	0.7	2.51	2.28			
15	5:35A	26592	1.9	51	3.22	26	0.3	38	0.49	58	3.66															0.01	0.018	0.74	2.67	2.41			
16	5:00A	28492	1.847	51	3.31	25	0.29	40	0.52	42	2.73															0.01	0.016	0.74	2.28	2.02			
17	5:35A	30339	1.901	53	3.34	25	0.29	45	0.56	56	3.33															0.01	0.013	0.7	2.35	2.04			
18	6:00A	32240	1.855	52	3.39	25	0.29	42	0.54	55	3.59	95														0.01	0.013	0.7	2.67	2.21			
19	9:00A	34075	1.772	54	3.65	25	0.3	37	0.5	42	2.84																						
20	9:00A	35847	1.913	53	3.32	26	0.29	36	0.45	55	3.44															0.01	0.019	0.68	2.27	1.93			
21	6:00A	37760	1.863	43	2.62	27	0.29	40	0.48	41	2.5															0	0.017	0.7	2.37	1.9			
22	9:00A	39723	2.023	61	3.61	30	0.32	42	0.49	68	4.03															0	0.024	0.93	1.76	1.46			
23	11:00A	41746	1.806	43	2.82	21	0.25	30	0.39	45	2.95															0	0.021	0.99	2.56	2.09			
24	8:00A	43572	2.021	51	3.02	25	0.28	50	0.59	59	3.9															0	0.021	0.99	2.56	2.09			
25	8:00A	45093	2.094	38	2.17	24	0.24	34	0.38	48	2.74	766														0.03	0.016	0.84	2.45	2.15			
26	8:00A	47687	1.739	48	3.31	23	0.29	26	0.36	54	3.72																						
27	5:45A	49423	1.973	54	3.28	25	0.28	43	0.62	67	4.07															0	0.016	0.75	2.11	1.64			
28	5:40A	51396	2.051	54	3.18	26	0.28	56	0.65	54	3.16															0.01	0.02	0.78	2.6	2.3			
29	5:30A	53447	2.223	54	2.91	26	0.25	36	0.39	41	2.21	116														0.01	0.017	0.71	1.91	1.28			
30	5:45A	55870	1.968	45	2.74	26	0.29	38	0.46	45	2.74															0.01	0.025	0.72	2.69	2.39			
31																																	
TOT		878231	56.866	1477	58.64		2.59	1142	14.64	1490	46.14	0	0	688	0	0	0	270	199.6	0	0	1.93	5.689	165.4	24.24	0	0	0.17	0.388	16.77	70.46		
MAX	0	85670	2.223	61	3.97	30	0.35	56	0.65	68	4.07	0	0	167	0	0	0	42	7.34	0	0	0.12	0.281	7.65	1.36	0	0	0.03	0.025	0.93	2.71	2.67	0
MIN	0	2180	1.512	38	2.17	20	0.23	26	0.36	39	2.21	0	0	95	0	0	0	42	7.15	0	0	0.07	0.228	7.38	0.9	0	0	0	0.012	0.65	1.49	1.24	0
AVE	#DIV/0!	25207.7	1.8622	49.23	3.168	24.57	0.288	36.07	0.488	49.57	3.205	137.6	0	0	0	0	0	42	7.253	0	0	0.086	0.269	7.509	1.102	0	0	0.008	0.018	0.744	2.348	2.07	0

*Enter Final Reading Last Month

POINT OF APPLICATION: Main Pump Station

METER LOCATION: Main Pump Station

Pre & Post Filters

Post Filter

Pre Filter

Post Filter

% Fluoride Solution Fed

% Solution Fed

% Solution Fed

CHLORINE

Type of Chlorine Used:

X Chlorine Gas

Calcium Hypochlorite

Sodium Hypochlorite

Chlorine Test Kit Used Hach DPD

FLUORINATION

Type of Fluoride Used:

X Hydrofluoric Acid, HF

Sodium Fluoride

Other

Type of Test Instrument Used: Hach SPADNS

This Agency is Authorized to require this information under Ill. Rev. Stat., 1979, Chapter 111 1/2, Section 10-18. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continues, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the Forms Management Center.

I certify that the information in this report is complete and accurate to the best of my knowledge.

Reported by: (Signature) Date

Checked by: (Signature) Date

9/11/0543 7-1-22

Phone: 815.233.5088 Date Monthly Done by: RGC LABS - Backwash Dept

DIVISION OF PUBLIC WATER SUPPLIES

CITY OF LA SALLE PUBLIC WATER SUPPLY
FOR MONTH OF November 2022

RAW WATER				CHEMICALS APPLIED								FILTERS				CHEMICAL TESTS												REMARKS						
Meter Read AM	Reading (1000 gal.)	Treated (1000 gal.)	Used lbs. of Gal.	Chlorine		Fluoride		Na/MnO4		Ortho Phosphate		Each day indicate total previous backwash, if backwashed at mid-day, indicate hours previous/ hours following	Wash Water Used Gal.	RAW						FINISHED														
				Used lbs. of Gal.	Calc mg/l			pH	Alk. as CaCO3 mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	pH	Ortho Phosphate mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	P mg/l	Cl res. F = free T = total															
a	b	c	d	e	f	g	h	i	j	k	l	m	n	o	p	q	r	s	t	u	v	w	x	y	z	aa	bb		cc	dd	ee	ff	gg	hh
1	5:30A	60108	1.664	48	3.46	18	0.24	46	0.66	35	2.52			7.19		0.11	0.433	7.48	1.21							0.01	0.021	0.67	2.27	1.84				
2	5:40A	1664	1.897	52	3.29	25	0.19	69	0.87	43	2.72			7.22		0.13	0.466	7.5	1.28							0.01	0.021	0.73	2.36	1.98				
3	6:30A	3561	1.901	45	2.83	19	0.21	55	0.69	42	2.64			7.19		0.13	0.467	7.38	1.15							0.01	0.016	0.79	2.32	2.01				
4	7:00A	5462	1.717	40	2.79	18	0.22	49	0.68	34	2.37			7.1		0.15	0.459	7.32	1.18							0.01	0.016	0.96	1.81	1.74				
5	7:50A	8896	1.679	55	3.92	20	0.25	72	1.02	46	3.28																							
6	8:30A	10575	1.794	44	2.84	16	0.19	50	0.67	31	2.07	120	49																					
7	5:40A	12469	1.892	46	2.92	15	0.17	40	0.61	38	2.41			7.06		0.08	0.429	7.31	1.18							0.01	0.019	0.79	2.33	2.12				
8	5:45A	14261	1.616	44	3.26	17	0.23	44	0.55	38	2.82			7.23		0.07	0.447	7.43	1.21							0.01	0.016	0.99	2.74	3.4				
9	5:45A	15877	1.892	47	3.35	16	0.21	50	0.71	47	3.35			7.32		0.09	0.421	7.71	1.28							0.01	0.016	0.94	2.18	2.02				
10	6:00A	17569	1.648	40	2.6	18	0.21	54	0.7	43	2.79	95	50	7.28		0.08	0.42	7.56	0.92							0.01	0.016	0.77	2.32	2.02				
11	5:55A	19407	1.789	31	2.08	15	0.18	44	0.59	40	2.68																							
12	5:50A	21196	1.62	40	2.96	17	0.23	44	0.55	35	2.58																							
13	6:00A	22818	1.558	48	3.68	17	0.24	39	0.91	48	3.69																							
14	5:30A	24374	1.926	45	2.79	18	0.2	52	0.68	41	2.54	95	50	7.1		0.1	0.418	7.42	0.95						0.01	0.017	0.7	2.22	1.81					
15	5:35A	26310	1.892	40	2.83	17	0.22	41	0.58	39	2.76			7.27		0.1	0.407	7.43	0.98							0.01	0.021	0.86	2.77	2.41				
16	5:35A	28202	1.847	40	3.1	21	0.3	55	0.85	34	2.64			7.26		0.12	0.448	7.53	0.96							0.01	0.003	0.71	2.27	1.98				
17	5:45A	29549	1.615	43	3.19	21	0.28	65	0.97	48	3.56			7.26		0.11	0.458	7.47	1.22							0.01	0.024	0.72	2.08	1.52				
18	5:35A	31134	1.982	42	2.54	23	0.25	53	0.64	39	2.3	94	50	7.28		0.09	0.431	7.45	1.18							0.01	0.028	0.75	1.54	1.27				
19	6:55A	33146	1.799	39	2.74	19	0.24	48	0.67	40	2.81																							
20	6:55A	34855	1.596	38	2.85	17	0.23	53	0.8	40	3.01																							
21	5:40A	36451	1.974	39	2.97	20	0.26	62	0.94	53	4.04			7.22		0.11	0.477	7.34	0.95						0.02	0.02	0.79	2.61	2.24					
22	5:50A	38025	2.024	37	2.19	21	0.23	63	0.75	39	2.31			7.29		0.1	0.443	7.41	0.85							0.01	0.026	0.66	1.3	0.93				
23	5:35A	40049	1.895	42	2.65	23	0.26	64	0.8	47	2.97	117	50	7.1		0.14	0.482	7.44	1.22							0.01	0.028	0.8	1.53	1.31				
24	7:30A	41944	1.922	39	2.43	21	0.23	61	0.78	45	2.8																							
25	8:00A	43866	1.820	32	2.1	17	0.2	47	0.61	38	2.49																							
26	7:30A	45992	1.59	37	2.79	20	0.27	56	0.84	37	2.79																							
27	8:00A	47262	1.632	27	1.98	16	0.2	38	0.56	34	2.5																							
28	5:30A	48914	1.938	45	3.5	25	0.35	69	1.07	67	4.44	117	50	7.03		0.11	0.41	7.3	0.85						0.02	0.027	0.87	1.71	1.48					
29	7:30A	50452	1.626	34	2.51	18	0.24	49	0.72	33	2.43			7.04		0.08	0.395	7.13	0.95							0	0.03	0.96	1.84	1.59				
30	5:30A	52078	1.626	31	2.29	17	0.23	54	0.8	35	2.58			7.02		0.12	0.46	7.4	1.23							0.02	0.016	0.87	2.11	1.66				
31																																		
TOT.	0	865872	51.987	1230	85.54		7.17	1619	22.47	1218	84.9	0	0	731	0	0	0	0	348	1.963	0	0	2.02	8.922	141	20.78	0	0	0.21	0.386	14.931	62.36	1	
MAX.	0	60108	2.024	55	3.92	26	0.36	72	1.07	67	4.44	0	0	120	0	0	0	0	50	2.32	0	0	0.15	0.477	7.71	0.28	0	0	0.02	0.03	0.96	2.77	2.41	0
MIN.	0	1664	1.538	27	1.99	15	0.17	38	0.56	31	2.07	0	0	93	0	0	0	0	49	7.02	0	0	0.07	0.299	7.13	0.95	0	0	0	0.053	0.66	1.3	0.93	0
AVE.	KDVI07	28962.4	1.7329	41	2.851	19.03	0.235	53.97	0.749	40.6	2.83	average	average	104.4	average	average	average	average	49.71	7.172	average	average	0.106	0.438	7.422	1.093	average	average	0.011	0.02	0.798	2.079	1.742	average

*Enter Final Reading Last Month

POINT OF APPLICATION: Pre & Post Filters, Post Filter, Pre Filter, Post Filter

METER LOCATION: Main Pump Station

2. % Fluoride Solution Fed

3. % Solution Fed

4. % Solution Fed

CHLORINE
Type of Chlorine Used:

Chlorine Gas
 Calcium Hypochlorite
 Sodium Hypochlorite

Chlorine Test Kit Used Hach DPD

FLUORIDATION
Type of Fluoride Used:

Hydrofluoric Acid, 50%
 Sodium Fluoride
 Other

Type of Test Instrument Used: Hach SPADNS

This Agency is Authorized to require this information under Ill. Rev. Stat., 1976, Chapter 111, 1/2, Section 1516. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continues, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the Forms Management Center.

I certify that the information in this report is complete and accurate to the best of my knowledge.

BDR 9110543 12-2-2022
Reported by: (Signature) Cert or Reg Number Date
Phone: 815.223.0086 Date Monthly Check by: PDC LABS Bacterias Sent

DIVISION OF PUBLIC WATER SUPPLIES

ON CITY OF LA SALLE PUBLIC WATER SUPPLY
FOR MONTH OF JANUARY 2024

Meter Read AM	RAW WATER			CHEMICALS APPLIED								FILTERS				CHEMICAL TESTS											REMARKS									
	Reading (1000 gal.)	Treated (1000 gal.)	Chlorine		Fluoride		NaMnO4		Ortho Phosphate		Each day indicate total previous backwash. If backwashed at mid-day, indicate hours previous/ hours following.				Wash Water Used Gal.	RAW					FINISHED															
			Used lbs. or Gal.	Calc mg/l	Used lbs. or Gal.	Calc mg/l	Used lbs. or Gal.	Calc mg/l	Used lbs. or Gal.	Calc mg/l						pH	Alk. as CaCO3 mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	pH	Ortho Phosphate mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	F mg/l		Cl res. F = free T = total								
			1	2	3	4	aa	bb	cc	dd	ee	ff	gg	hh																						
a	b	c	d	e	f	g	h	i	j	k	l	m	n	o	p	q	r	s	t	u	v	w	x	y	z	aa	bb	cc	dd	ee	ff	gg	hh	ii		
1	9:00A	40351	1,379	589	6.25	28	0.44	63	1.1	68	5.91																									
2	5:50A	1224	1,715	596	5	26	0.33	56	0.78	50	3.5																									
3	5:50A	3094	1,511	555	5.28	25	0.36	57	0.9	62	4.92																									
4	5:50A	4605	1,512	508	4.83	25	0.36	53	0.84	61	4.54																									
5	5:50A	6117	1,913	789	5.78	33	0.38	63	1.04	30	1.88																									
6	8:00A	8030	2,087	816	4.25	29	0.3	71	0.82	73	4.19																									
7	8:05A	10117	1,515	557	5.29	23	0.33	53	0.84	63	4.99																									
8	6:00A	11832	1,451	525	5.21	24	0.36	51	0.84	58	4.79																									
9	5:50A	13083	1,862	612	4.73	27	0.32	68	0.88	61	3.93																									
10	5:55A	14945	1,938	617	4.58	28	0.31	60	0.74	72	4.45																									
11	7:20A	16883	1,351	587	6.25	28	0.45	60	1.07	70	8.21																									
12	5:45A	18234	1,594	734	6.62	33	0.45	84	1.26	72	5.41																									
13	10:00A	19828	1,769	542	4.4	26	0.32	79	1.07	65	4.4																									
14	11:30A	21597	1,577	257	2.34	16	0.22	45	0.58	41	3.11																									
15	6:30A	23174	1,522	509	4.81	30	0.43	86	1.36	74	5.83																									
16	5:50A	24696	1,575	525	4.8	28	0.39	74	1.13	84	4.87																									
17	6:25A	26271	1,919	564	4.23	28	0.32	78	0.97	71	4.44																									
18	5:55A	28190	1,827	604	5.34	27	0.36	65	0.96	77	5.67																									
19	5:45A	29817	1,566	660	5.06	28	0.36	84	0.98	79	6.05																									
20	8:00A	31383	1,816	572	4.53	24	0.29	57	0.75	71	4.69																									
21	8:00A	33199	1,748	368	3.03	26	0.32	62	0.65	72	4.94																									
22	5:50A	34947	1,858	594	5.15	25	0.33	53	0.76	67	4.81																									
23	6:00A	36605	1,851	457	3.55	22	0.26	48	0.62	60	3.89																									
24	5:55A	38456	1,523	578	5.46	28	0.4	58	0.91	80	6.3																									
25	5:50A	39979	1,988	562	4.26	25	0.29	52	0.68	72	4.55																									
26	5:50A	41877	1,817	605	5.38	26	0.35	52	0.77	76	5.63																									
27	7:00A	43494	1,519	595	5.87	23	0.32	45	0.71	84	5.05																									
28	7:00A	45013	1,905	488	3.69	21	0.24	42	0.53	59	3.71																									
29	5:55A	46918	1,35	674	6.12	26	0.42	51	0.91	84	7.46																									
30	5:50A	48268	2,088	606	4.18	25	0.26	51	0.59	62	3.56																									
31	5:45A	50356	1,338	612	6.58	25	0.41	50	0.9	72	6.45																									
TOT.	0	812383	51,694	###	154	10.7	1871	27.2	2050	150	0	0	744	0	0	0	481	163	0	0	2.35	8.77	170	55.3	0	0	0.28	2.17	22.3	50.2	1					
MAX.	0	50356	2,088	769	6.62	33	0.45	86	1.36	84	7.48	0	0	49	0	0	25	7.55	0	0	0.18	0.48	7.9	2.1	0	0	0.03	0.14	1.06	3.31	3.08	0				
MIN.	0	1224	1,338	257	2.34	16	0.22	42	0.53	30	1.88	0	0	22	0	0	24	7.22	0	0	0.01	0.34	7.5	1.98	0	0	0	0.03	0.85	0.69	0.47	0				
AVE.	#DIV/0!	26205.9	1,667548	556	4.96	26	0.34	60.4	0.58	66.1	4.85	###	###	37.2	###	###	###	24.6	7.39	###	###	0.11	0.4	7.74	1.84	###	###	0.01	0.07	0.88	1.62	1.37	###			

*Enter Final Reading Last Month

Pre & Post Filters

Post Filter

Pre Filter

Post Filter

POINT OF APPLICATION

METER LOCATION: Main Pump Station

2. % Fluoride Solution Fed

3. % Solution Fed

4. % Solution Fed

CHLORINE

Type of Chlorine Used:

X Chlorine Gas %

Calcium Hypochlorite %

Sodium Hypochlorite %

Chlorine Test Kit Used Hach DPD

FLUORIDATION

Type of Fluoride Used:

X Hydrofluosilicic Acid, %F %

Sodium Fluoride %

Other %

Type of Test Instrument Used: Hach SPADNS

This Agency is Authorized to require this information under Ill. Rev. Stat., 1979, Chapter 111 1/2, Section 1019. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continues, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the Forms Management Center.

I certify that the information in this report is complete and accurate to the best of my knowledge

Recorded by: (Signature) _____ Cert or Reg Number _____ Date _____

Phone: 815.223.0066 Date Monthly Done by: PDC LABS Bacterials Dept

DIVISION OF PUBLIC WATER SUPPLIES

CITY OF LASALLE PUBLIC WATER SUPPLY
FOR MONTH OF JANUARY 2023

a	RAW WATER			CHEMICALS APPLIED								FILTERS				CHEMICAL TESTS												REMARKS								
	Meter Read AM	Reading (1000 gal.)	Treated (1000 gal.)	Chlorine		Fluoride		NaMnO4		Ortho Phosphate		Wash Water Used Gal.	RAW						FINISHED																	
				Used lbs. or Gal.	Calc mg/l		Used lbs. or Gal.	Calc mg/l	pH	Alk. as CaCO3 mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	pH	Ortho Phosphate mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	F mg/l	Cl res. F = free T = total																
	b	c	d	e	f	g	h	i	j	k	l	m	n	o	p	q	r	s	t	u	v	w	x	y	z	aa	bb		cc	dd	ee	ff	gg	hh		
1	5-45A	55774	1764	40	3.72	22	0.27	59	0.8	32	2.18																							2.15	1.73	1322 lbs 42 lbs used
2	5-45A	1784	1757	40	2.67	20	0.24	57	0.76	39	2.6		118																						845 lbs 40 lbs used	
3	5-40A	3561	1919	37	2.31	21	0.24	60	0.75	44	2.75			7.2																					2351 lbs 40 lbs used	
4	6-30A	5490	1793	39	2.6	22	0.27	73	0.98	38	2.54			7.25																					1903 lbs 37 lbs used	
5	5-40A	7273	199	39	2.35	21	0.23	63	0.76	43	2.59			7.24																						1431 lbs 30 lbs used
6	5-55A	9263	1875	43	2.74	24	0.27	67	0.85	48	3.05		98	50	7.2																				6672818 lbs 39 lbs used	
7	10-00A	11138	1745	30	2.08	17	0.21	46	0.53	29	1.99																								2206 LBS 43 LBS USED	
8	8-00A	12983	1632	31	2.28	17	0.23	46	0.58	30	2.2																								1941 LBS 30 LBS USED	
9	5-32A	14515	1695	41	2.9	22	0.28	72	1.02	44	3.11			7.22																					1567 lbs 31 lbs used	
10	5-55A	16210	2041	39	2.29	22	0.23	61	0.72	47	2.76			7.26																					1076 lbs 41 lbs used	
11	6-05A	18251	1886	41	2.6	24	0.28	72	0.91	60	3.81			7.29																					61402840 lbs 39 lbs used	
12	6-10A	20137	2246	42	3.5	24	0.17	72	0.56	50	1.93		142	50	7.22																				2348 lbs 41 lbs used	
13	6-05A	22383	136	36	2.2	19	0.21	59	0.72	35	2.14			7.2																					19472304 lbs 42 lbs used	
14	5-45A	24343	1775	36	2.43	20	0.25	60	0.81	42	2.84																								1873 lbs 36 lbs used	
15	5-40A	26118	1861	32	2.08	20	0.23	50	0.68	41	2.64																								1439 lbs 36 lbs used	
16	5-45A	27979	1649	28	2.33	21	0.28	72	1.05	36	2.62			7.22																					10512663 lbs 32 lbs used	
17	5-50A	29528	1936	33	2.04	19	0.21	75	0.93	48	2.97			7.23																					2352 lbs 25 lbs used	
18	6-05A	31964	186	30	1.93	21	0.25	63	0.81	35	2.26		142	50	7.15																				1958 lbs 33 lbs used	
19	5-35A	32424	1923	24	1.5	19	0.22	63	0.79	42	2.62			7.21																					1699 lbs 30 lbs used	
20	5-55A	32547	1615	28	2.07	22	0.29	60	0.93	23	3.93			7.14																					13102031 lbs 24 lbs used	
21	6-00A	36962	2224	28	1.5	20	0.19	37	0.39	43	2.31																								2491 LBS 28 LBS USED	
22	10-00A	39186	1938	24	1.5	17	0.19	43	0.30	38	2.33																								2154 LBS 28 LBS USED	
23	6-10A	41124	1686	22	1.56	20	0.26	43	0.51	39	2.77			7.26																					1867 lbs 24 lbs used	
24	5-30A	42810	1684	33	2.1	24	0.27	84	1.08	46	2.92		143	50	7.2																				1609 lbs 22 lbs used	
25	9-00A	44894	2191	26	1.42	20	0.2	66	0.72	34	1.86																									1217 LBS 33 LBS USED
26	6-55A	46885	204	23	1.35	21	0.22	42	0.49	29	2.29			7.25																					910 2616 LBS 26 LBS USED	
27	5-35A	48525	2093	19	1.33	17	0.18	45	0.53	41	2.43			7.19																					2339 lbs 23 lbs used	
28	6-00A	50949	1822	22	1.45	17	0.2	42	0.56	37	2.43																								2114 lbs 19 lbs used (CL2 pump not operating)-Replaced	
29	6-00A	52770	1743	25	2	20	0.25	56	0.77	48	3.3																								1852 lbs 22 lbs used	
30	5-40A	54513	2071	31	1.79	20	0.21	58	0.67	44	2.55		142	50	7.24																				1499 lbs 29 lbs used	
31	5-35A	56584	2053	29	1.69	22	0.23	59	0.69	27	3.33			7.25																					11292820 lbs 31 lbs used	
TOT	0	922436	58.937	995	297.7		7.26	1811	23.15	1302	82.08	0	0	785	0	0	0	300	151.7	0	0	1.05	18.576	159.6	22.05	0	0	0.33	0.513	16.93	69.98	1				
MAX	0	56584	2246	43	2.95	24	0.29	84	1.06	63	3.93	0	0	143	0	0	0	50	7.29	0	0	0.19	1.924	7.7	1.29	0	0	0.03	0.348	0.97	3.27	2.91	0			
MIN	0	1784	1.615	19	1.13	17	0.17	37	0.39	29	1.86	0	0	98	0	0	0	53	7.14	0	0	0.01	0.229	7.45	0.84	0	0	0.01	0.059	0.66	0.31	0.11	0			
AVE	#DIV/0!	29756	1.8915161	32.1	1.604	20.48	0.234	59.06	0.747	42	2.948	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent	Percent		

*Enter Final Reading Last Month	Pre & Post Filters	Post Filter	Pre Filter	Post Filter
POINT OF APPLICATION				
METER LOCATION: Main Pump Station				
2. % Fluoride Solution Fed				
3. % Solution Fed				
4. % Solution Fed				

CHLORINE
Type of Chlorine Used:

Chlorine Gas _____ %
 Calcium Hypochlorite _____ %
 Sodium Hypochlorite _____ %

Chlorine Test Kit Used: Hach DPD

FLUORIDATION
Type of Fluoride Used:

K Hydrofluoric Acid 5F _____ %
 Sodium Fluoride _____ %
 Other _____ %

Type of Test Instrument Used: Hach SPADNS

The Agency is Authorized to require this information under its: Rev. Stat., 1979, Chapter 111 1/2, Section 1019. Obstruction of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continues, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the Forms Management Center.

I certify that the information in this report is complete and accurate to the best of my knowledge.

BDP 9/110543 2-2-23

Reported by: (Signature) _____ Cert or Reg Number _____ Date _____
 Phone: 815 222 5088 Date Started/ Done by: PSC LABS Bartlett, Ill

DIVISION OF PUBLIC WATER SUPPLIES

a	RAW WATER			CHEMICALS APPLIED								FILTERS				CHEMICAL TESTS												REMARKS				
	Meter Read AM	Reading (1000 gal.)	Treated (1000 gal.)	Chlorine		Fluoride		NaMnO4		Ortho Phosphate		Each day indicate total previous backwash. If backwashed at mid-day, indicate hours previous hours following.				Wash Water Used Gal.	RAW						FINISHED									
				Used lbs. or Gal.	Calc mg/l	1	2	3	4		pH	Alk. as CaCO3 mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	pH	Ortho Phosphate mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	F mg/l		Cl res. F = free T = total									
				mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l		mg/l	mg/l		
1	5-50A	43732	1489	384	3.71	21	0.31	42	0.68	47	3.78					7.38		0.01	0.333	7.84	1.26					0.01	0.02	0.72	2.45	2.11		
2	5-55A	1489	1425	411	4.15	19	0.29	46	0.77	46	3.87					7.35		0.02	0.277	7.84	1.25					0.03	0.016	0.77	2.49	2.1		
3	5-45A	2914	1505	472	4.23	19	0.25	61	0.91	48	3.58			91		7.39		0.01	0.311	7.86	1.18					0.02	0.019	0.72	2.39	2.01		
4	7-00A	4519	1539	380	3.33	17	0.22	40	0.58	43	3.14																					
5	7-30A	6158	1341	348	3.73	14	0.23	39	0.7	34	3.04																					
6	5-40A	7499	1418	443	4.5	19	0.25	51	0.88	58	4.5					7.34		0.03	0.205	7.85	1.24					0.02	0.018	0.71	2.24	1.88		
7	5-55A	8917	1759	405	3.3	23	0.28	47	0.64	42	2.85					7.34		0.02	0.285	7.81	0.96					0.02	0.031	0.63	1.91	1.3		
8	5-55A	10686	159	410	3.71	23	0.32	47	0.71	41	3.09			122		7.37		0.02	0.341	7.83	1.35					0.02	0.021	0.81	2.24	1.56		
9	5-55A	12278	1514	348	3.31	20	0.25	38	0.5	41	3.25					7.37		0.02	0.28	7.86	1.02					0.02	0.029	0.77	2.41	2.08		
10	5-55A	13790	1.3	439	4.86	25	0.42	57	1.05	49	4.52					7.26		0.02	0.304	7.81	0.96					0.02	0.019	0.97	2.45	2.05		
11	5-45A	15060	1.784	322	2.6	18	0.22	38	0.51	42	2.82																					
12	5-50A	16874	1.32	388	4.23	24	0.4	50	0.91	33	3																					
13	6-05A	18194	1.425	422	4.28	24	0.37	50	0.94	43	3.82			115		7.32		0.05	0.205	7.85	1.24					0.02	0.016	0.85	2.05	1.7		
14	6-00A	19619	1.527	473	4.48	27	0.35	55	0.96	49	3.85					7.31		0.06	0.21	7.78	1.22					0.01	0.02	0.82	1.96	1.61		
15	5-45A	21146	1.82	359	3.98	31	0.25	43	0.57	42	2.77					7.36		0.06	0.255	7.7	1.27					0.02	0.029	0.81	1.88	1.55		
16	5-55A	22956	1.409	434	4.43	32	0.34	44	0.75	38	3.23					7.23		0.08	0.24	7.59	0.98					0.03	0.014	0.75	2.05	1.71		
17	5-50A	24375	1.414	535	5.44	38	0.42	64	1.08	53	4.49			95		7.4		0.05	0.244	7.7	1.2					0	0.021	0.8	1.89	1.51		
18	6-00A	25789	1.801	430	3.43	22	0.28	46	0.63	46	3.06																					
19	6-05A	27590	1.503	342	3.27	18	0.28	36	0.57	27	2.15																					
20	5-40A	29093	1.359	451	4.88	23	0.32	51	0.9	49	4.32					7.33		0.08	0.278	7.71	1.15					0.01	0.024	0.67	1.79	1.42		
21	5-40A	30452	1.524	458	4.52	25	0.35	52	0.82	57	4.48					7.29		0.07	0.306	7.7	0.95					0.01	0.024	0.75	2.05	1.72		
22	5-40A	31876	1.535	464	3.94	32	0.28	45	0.59	41	2.58			118		7.27		0.07	0.285	7.68	1.24					0.03	0.031	0.75	1.56	1.21		
23	5-55A	33811	1.488	479	4.6	25	0.38	49	0.78	50	4					7.21		0.12	0.228	7.67	1.13					0.02	0.029	0.79	2.01	2.28		
24	6-05A	35309	1.552	428	3.97	19	0.27	36	0.9	35	2.7					7.32		0.07	0.277	7.73	1.24					0.01	0.023	0.72	2.49	2.14		
25	6-10A	36861	1.587	434	3.99	23	0.32	52	0.8	52	3.98																					
26	6-00A	38428	1.948	431	3.77	22	0.29	45	0.65	35	2.77																					
27	5-55A	40074	1.418	424	4.3	21	0.32	43	0.73	47	3.97			117		7.23		0.14	0.235	7.68	1.14					0.02	0.026	0.94	2.21	1.82		
28	5-40A	41492	1.535	421	3.7	23	0.31	53	0.78	41	3.01					7.25		0.07	0.29	7.66	0.95					0.02	0.022	0.73	2.6	2.24		
29	5-45A	43127	1.512	493	4.89	23	0.33	63	1	49	3.89					7.46		0.02	0.282	7.7	1.22					0.02	0.014	0.83	2.62	2.29		
30	5-55A	44635	1.753	462	3.79	23	0.29	42	0.57	42	2.87					7.19		0.08	0.258	7.59	0.94					0.01	0.017	0.76	2.3	2		
31	5-55A	46392	1.527	484	4.37	23	0.32	44	0.69	43	3.37					7.12		0.06	0.262	7.57	1.19					0.01	0.015	0.75	2.02	1.6		
TOT	0	755277	47 919	13195	124.1		9.62	1493	23.44	1396	107.1	0	0	658	0	0	300	168.1	0	0	1.23	5.194	953.3	26.17	0	0	0.4	0.484	17.72	66.72	1	
MAX	0	46392	1.835	535	5.44	28	0.43	64	1.08	58	4.9	0	0	122	0	0	50	7.46	0	0	1.14	0.341	7.83	1.27	0	0	0.03	0.031	0.97	2.71	2.37	0
MIN	0	1489	1.3	322	2.9	14	0.21	36	0.51	22	2.15	0	0	91	0	0	50	7.12	0	0	0.01	0.205	7.57	0.94	0	0	0	0.014	0.53	1.56	1.09	0
AVE	WDV/24	24263.774	1.5457742	425.61	4.002	21.91	0.31	48.16	0.756	44.06	3.453	#####	#####	109.7	#####	#####	50	7.307	#####	#####	0.053	0.269	41.45	1.136	#####	#####	0.017	0.021	0.77	2.249	1.864	#####

This Agency is Authorized to enforce this information under St. Rev. Stat., 1978, Chapter 111.02, Section 1079. Obstruction of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continues, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the Forms Management Center.

I certify that the information in this report is complete and accurate to the best of my knowledge.

B.P.R. 9116543 4-3-23
 Reported by: (Signature) _____ Date: _____
 City or Reg Number: _____ Date Monthly: _____ by: POC LABS. Backlog: _____
 Phone: 815.223.0098

ON CITY OF LA SALLE PUBLIC WATER SUPPLY
FOR MONTH OF May 2023

DIVISION OF PUBLIC WATER SUPPLIES

Meter Read AM	RAW WATER			CHEMICALS APPLIED								FILTERS				CHEMICAL TESTS														REMARKS Use reverse side for additional remarks					
	Reading (1000 gal.)	Treated (1000 gal.)	Chlorine Used lbs. of Gal.	Calc mg/l	Fluoride Used lbs. of Gal.	Calc mg/l	NaMnO4 Used lbs. of Gal.	Calc mg/l	Ortho Phosphate		Used lbs. of Gal.	Calc mg/l	Wash Water Used Gal.	RAW							FINISHED														
									Used lbs. of Gal.	Calc mg/l				pH	Alk. as CaCO3 mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	pH	Ortho Phosphate mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	F mg/l	Cl res. mg/l F = free T = total										
a	b	c	d	e	f	g	h	i	j	k	l	m	n	1	2	3	4	s	t	u	v	w	x	y	z	aa	bb	cc	dd	ee	ff	gg	hh		
1	6:00A	52517	1.813	482	3.83	23	0.28	45	0.8	45	2.98			192				46	7.24		0.15	0.308	7.65	1.15			0.03	0.036	0.95	2.08	1.97				
2	6:05A	1813	1.7	439	3.72	22	0.28	44	0.62	48	3.39								7.26		0.06	0.316	7.62	1.26			0.03	0.026	0.8	2.86	2.43				
3	5:25A	3513	2.024	539	3.83	26	0.28	57	0.68	60	3.55								7.24		0.09	0.274	7.59	1.22			0.02	0.024	0.81	2.98	2.63				
4	6:30A	5537	1.886	469	4	21	0.27	42	0.6	43	3.05								7.35		0.09	0.288	7.7	1.2			0.01	0.037	0.7	1.58	1.08				
5	6:55A	7225	1.423	528	5.14	25	0.36	46	0.78	53	4.47								7.28		0.18	0.304	7.69	1.07			0.02	0.033	0.82	2.46	2.14				
6	5:45A	8648	1.862	542	4.19	27	0.32	55	0.71	57	3.67																								
7	5:45A	10510	2.001	449	3.23	42	0.46	36	0.46	45	2.7																								
8	5:55A	12511	1.767	483	3.93	23	0.26	42	0.57	49	3.03			187				46	7.31		0.09	0.278	7.64	1.05			0.02	0.026	0.87	2.49	2.05				
9	5:30A	14278	1.87	563	4.33	27	0.31	49	0.63	50	3.21								7.35		0.23	0.272	7.75	1.04			0.02	0.024	0.79	2.79	2.48				
10	5:45A	16148	1.958	587	4.23	34	0.31	55	0.66	61	3.86								7.4		0.08	0.291	7.77	1.11			0.02	0.024	0.8	2.89	2.43				
11	6:10A	18146	1.946	523	3.87	26	0.29	44	0.54	53	3.27								7.32		0.23	0.252	7.73	1.18			0.02	0.028	0.78	2.25	2.05				
12	5:25A	20052	1.853	549	4.19	26	0.3	52	0.66	52	3.21								7.31		0.09	0.286	7.72	1.19			0.02	0.027	0.78	2.35	2.01				
13	6:00A	21975	2.027	524	3.71	25	0.26	62	0.81	58	3.43																								
14	7:30A	24002	1.683	417	3.57	25	0.32	35	0.5	41	2.92																								
15	5:30A	25685	1.756	464	3.8	22	0.27	43	0.59	42	2.87			168				47	7.32		0.09	0.314	7.76	1.25			0.02	0.027	0.81	2.5	2.28				
16	5:35A	27441	1.964	489	3.58	24	0.27	48	0.59	53	3.24								7.25		0.11	0.315	7.7	1.25			0.02	0.021	0.83	2.71	2.37				
17	5:45A	29405	1.718	504	4.22	24	0.3	43	0.6	48	3.35								7.28		0.09	0.31	7.71	1.07			0.01	0.018	0.76	2.33	2.03				
18	5:45A	31123	1.787	537	4.32	26	0.32	45	0.64	53	3.58								7.35		0.09	0.284	7.73	1.21			0.01	0.019	0.72	2.87	2.29				
19	5:45A	32910	2.092	608	4.17	28	0.29	49	0.54	53	3.03								7.37		0.1	0.281	7.74	1.08			0.01	0.018	0.7	2.67	2.3				
20	7:30A	35005	1.886	487	4.15	23	0.29	44	0.62	46	3.27																								
21	8:00A	36691	1.848	510	3.97	24	0.28	43	0.56	54	3.5																								
22	5:40A	38539	2.189	539	3.54	26	0.23	57	0.62	60	3.29			167				47	7.2		0.24	0.245	7.62	1.2			0.01	0.029	0.71	2.76	2.42				
23	5:55A	40728	1.998	506	3.79	25	0.27	49	0.59	56	3.36								7.13		0.05	0.287	7.58	1.32			0.02	0.026	0.78	2.21	1.84				
24	5:40A	42726	1.833	515	4.04	25	0.3	44	0.58	46	3.01								7.2		0.14	0.261	7.54	1.22			0.02	0.022	0.77	2.75	2.43				
25	5:40A	44559	2.191	454	2.98	22	0.22	46	0.5	60	3.28								7.23		0.14	0.268	7.67	1.09			0.03	0.038	0.69	2.66	2.3				
26	5:55A	46760	1.841	391	4.61	30	0.35	50	0.65	53	3.45			95				48	7.22		0.19	0.28	7.64	1			0.04	0.036	0.69	1.32	1.07				
27	8:00A	48591	1.824	567	4.47	26	0.31	50	0.65	56	3.81																								
28	8:30A	50415	2.085	449	3.05	23	0.24	41	0.47	41	2.35																								
29	6:45A	52550	1.748	473	3.89	25	0.31	44	0.6	53	3.64																								
30	6:00A	54248	1.871	476	3.66	32	0.37	53	0.68	61	3.91								7.3		0.11	0.304	7.45	1.22			0.02	0.027	0.77	2.12	1.93				
31	6:05A	56119	2.376	563	3.41	33	0.3	45	0.45	61	2.57								48	7.37		0.18	0.271	7.77	1.06			0.02	0.032	0.78	1.94	1.52			
TOT	0	913350	58495	18526	121.5	532	1458	38346	1603	1024	0	0	0	305	0	0	0	282	160.2	0	0	3.48	6.292	169	25.18	0	0	0.44	0.639	17.12	78.19	1			
MAX	0	56119	2.376	626	5.14	42	0.46	57	0.78	61	4.47	0	0	192	0	0	0	48	7.4	0	0	0.65	0.318	7.77	1.25	0	0	0.04	0.056	0.55	3.15	2.78	0		
MIN	0	1813	1.423	417	2.98	21	0.22	35	0.45	41	2.35	0	0	96	0	0	0	46	7.13	0	0	0.06	0.249	7.45	1	0	0	0.01	0.018	0.69	1.32	1.07	0		
AVE	#DIV/0!	29366.128	1.8869355	510.51	3.918	26.13	0.307	46.64	0.598	51.71	3.304	average	average	151.3	average	average	average	47	7.284	average	0.156	0.286	7.68	1.144	average	average	0.02	0.029	0.778	2.458	2.122	average			

*Enter Final Reading Last Month	Pre & Post Filters	Post Filter	Pre Filter	Post Filter
POINT OF APPLICATION:				
METER LOCATION: Main Pump Station				
2	% Fluoride Solution Fed			
3	% Solution Fed			
4	% Solution Fed			

CHLORINE Type of Chlorine Used:	FLUORIDATION Type of Fluoride Used:
Chlorine Gas Calcium hypochlorite % Sodium Hypochlorite 12.5 %	X Hydrochloric Acid % Sodium Fluoride % Other %
Chlorine Test Kit Used Hach DPD	Type of Test Instrument Used: Hach SPADNS

This Agency is Authorized to require this information under Ill. Rev. Stat., 1979, Chapter 111 1/2, Section 1016. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continues, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the Public Management Center.

I certify that the information in this report is complete and accurate to the best of my knowledge.

B.D.R. 9110543 6-1-2023
Reported by: (Signature) Date Monthly Date by POC: LABS Backman, Sent
Phone: 815 223 0288

CITY OF LASALLE
FOR MONTH OF JUNE 2023
PUBLIC WATER SUPPLY

DIVISION OF PUBLIC WATER SUPPLIES

a	RAW WATER			CHEMICALS APPLIED										FILTERS				CHEMICAL TESTS										REMARKS								
	Meter Read AM	Reading (1000 gal)	Treated (1000 gal)	Chlorine		Fluoride		Nakho4		Ortho Phosphate		Wash Water Used Gal.	pH	RAW				FINISHED																		
				Used lbs. or Gal.	Calc mg/l			Alk. as CaCO3 mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	pH	Ortho Phosphate mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	F mg/l	Cl res. F = free T = total																		
				1	2	3	4	5	6	7	8			9	10	11	12	13	14	15	16	17	18	19	20	21	22		23	24						
1	5:00A	56495	1539	497	3.69	17	0.19	45	0.56	61	3.77		7.26			0.17	0.267	7.71	1.05			0.01	0.017	0.83	2.62	2.23										
2	6:00A	1939	2159	562	3.75	33	0.33	45	0.5	56	3.11		7.26			0.19	0.264	7.72	1.24			0.01	0.022	0.83	2.48	2.13										
3	5:00A	4098	2001	547	3.93	32	0.35	45	0.54	64	3.84																									
4	6:10A	6099	231	636	3.34	32	0.3	45	0.47	57	2.86																									
5	6:05A	8409	1917	656	4.92	32	0.36	45	0.56	51	3.19	120	46	7.3		0.24	0.27	7.63	1.21			0.02	0.007	0.92	1.86	1.65										
6	6:30A	10326	1518	437	3.89	23	0.31	45	0.67	39	2.89			7.22		0.23	0.277	7.61	1.1			0	0.015	0.74	3.25	2.84										
7	5:30A	11944	2303	616	3.65	34	0.32	55	0.57	62	3.23			7.27		0.12	0.329	7.60	1.02			0.01	0.023	0.87	3.26	3.1										
8	6:15A	14247	1664	472	4.08	24	0.31	43	0.62	47	3.39			7.29		0.18	0.272	7.66	1.07			0.01	0.031	0.78	2.21	1.98										
9	6:40A	15911	2242	593	3.8	34	0.33	69	0.73	69	3.69	96	47	7.35		0.21	0.279	7.75	1.19			0.01	0.03	0.78	2.67	2.3										
10	6:00A	18153	1662	505	3.64	28	0.32	51	0.64	54	3.42																									
11	6:00A	20045	1504	345	2.61	19	0.22	36	0.45	38	2.27																									
12	6:20A	21949	1727	622	5.02	32	0.4	67	0.93	66	4.68			7.28		0.14	0.323	7.72	1.28			0.02	0.028	0.82	2.22	1.87										
13	6:00A	23676	2237	479	3.08	27	0.26	49	0.53	42	2.25			7.26		0.12	0.331	7.68	1.36			0.02	0.036	0.8	1.42	1.16										
14	6:55A	25913	1613	530	4.73	30	0.41	58	0.86	64	4.76	127	47	7.26		0.15	0.323	7.69	1.1			0.01	0.031	0.69	2.09	1.93										
15	5:55A	27526	2411	599	3.57	32	0.29	65	0.65	55	2.74			7.34		0.09	0.268	7.75	1.03			0.01	0.03	0.79	2.1	1.81										
16	6:29A	29937	1604	461	4.14	24	0.33	47	0.7	29	2.92			7.32		0.21	0.278	7.74	1.04			0.01	0.018	0.84	2.38	2.05										
17	6:35A	31541	2148	567	3.8	32	0.32	62	0.69	67	3.74																									
18	6:35A	33689	1811	416	3.31	23	0.28	43	0.57	43	2.85																									
19	5:45A	35500	1959	609	4.47	32	0.36	63	0.77	67	4.1	111	48	7.37		0.24	0.274	7.73	1.2			0.01	0.035	0.79	2.22	1.88										
20	5:50A	37459	2372	595	3.61	35	0.32	57	0.56	64	3.24			7.32		0.26	0.28	7.72	1.3			0.02	0.031	0.8	3.09	2.75										
21	6:00A	38631	2103	576	3.94	31	0.32	59	0.67	65	3.71			7.32		0.25	0.277	7.73	1.17			0.01	0.026	0.81	2.35	2.06										
22	5:45A	41934	1889	562	4.07	29	0.32	55	0.66	51	3.07			7.35		0.23	0.284	7.74	1.16			0.02	0.028	0.8	2.43	2.09										
23	6:00A	43923	2231	633	4.08	35	0.34	66	0.73	78	4.19	94	47	7.32		0.21	0.278	7.69	1.17			0.01	0.036	0.79	2.43	2.16										
24	6:00A	46154	2387	463	2.79	25	0.22	54	0.54	44	2.21																									
25	6:00A	48541	1531	489	4.3	26	0.37	48	0.75	51	3.99																									
26	5:55A	50072	2113	521	3.55	31	0.32	56	0.64	59	3.35			7.27		0.26	0.281	7.65	1.17			0.01	0.027	0.69	2.28	1.87										
27	5:45A	52165	1753	529	4.34	30	0.37	54	0.74	47	3.21			7.34		0.24	0.289	7.76	1.13			0.02	0.035	0.8	1.72	1.43										
28	6:50A	53938	2201	561	3.67	31	0.31	56	0.63	53	2.89	120	47	7.3		0.17	0.283	7.67	1.05			0.02	0.037	0.93	2.3	2.19										
29	6:15A	56139	1646	444	3.88	24	0.32	45	0.66	43	3.13			7.31		0.21	0.285	7.68	1.04			0.01	0.027	0.74	2.45	2.23										
30	5:35A	57785	1907	587	4.43	30	0.34	52	0.65	54	3.4			7.09		0.4	0.335	7.51	1.19			0.02	0.037	0.83	2.45	2.12										
31																																				
TOT	0	927158	59692	19960	116.8		9.54	1584	19.26	1648	100.1	0	0	667	0	0	0	0	262	160.4	0	0	4.54	6.347	199.2	25.32	0	0	0.29	0.642	17.67	70.41	1			
MAX	0	56495	2411	656	5.02	35	0.41	69	0.93	78	4.76	0	0	127	0	0	0	0	48	7.37	0	0	0.4	0.335	7.76	1.38	0	0	0.02	0.037	0.93	3.26	3.1	0		
MIN	0	1939	1531	348	2.61	17	0.19	36	0.45	36	2.21	0	0	94	0	0	0	0	46	7.09	0	0	0.09	0.264	7.51	1.02	0	0	0.015	0.69	1.42	1.16	0			
AVE	#QV/Q	30911.933	1.9897333	533	3.893	28.9	0.316	62.8	0.642	54.93	3.336	average	average	111.2	average	average	average	average	average	47	7.292	average	average	0.206	0.285	7.69	1.151	average	average	0.013	0.028	0.803	2.347	2.057	average	

This Agency is authorized to require this information under Ill. Rev. Stat., 1976, Chapter 111, 1/2, Section 1918. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continues, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the Farms Management Center.

I certify that the information in this report is complete and accurate to the best of my knowledge.

BDR 9110543 7-3-23
 (Required by 1918(a)(2)) Date Monthly Done by: FDOC LABS. Signature: Sami Date

DIVISION OF PUBLIC WATER SUPPLIES

ON CITY OF LA SALLE August 2023
FOR MONTH OF

PUBLIC WATER SUPPLY

RAW WATER				CHEMICALS APPLIED								FILTERS				CHEMICAL TESTS														REMARKS							
Meter Read AM	Reading (1000 gal)	Treated (1000 gal)	Chlorine		Fluoride		NaMnO4		Ortho Phosphate		Each day indicate total previous backwash. If backwashed at mid-day, indicate hours previous hours following				Wash Water Used Gal.	RAW							FINISHED														
			Used lbs. or Gal.	Calc mg/l	Used lbs. or Gal.	Calc mg/l	Used lbs. or Gal.	Calc mg/l	Used lbs. or Gal.	Calc mg/l	1	2	3	4		pH	Alk. as CaCO3 mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	pH	Ortho Phosphate mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	F mg/l	Cl res. F = Free T = Total										
a	b	c	d	e	f	g	h	i	j	k	l	m	n	o	p	q	r	s	t	u	v	w	x	y	z	aa	bb	cc	dd		ee	ff	gg	hh	ii		
1	6:40A	55040	2,253	440	2.81	23	0.22	44	0.47	46	2.45																										
2	6:45A	2253	1,358	550	5.62	23	0.45	48	0.85	46	4.66		138	46	7.32																						
3	6:10A	3511	2,183	424	2.79	24	0.34	46	0.51	43	2.36																										
4	5:30A	5794	1,277	592	6.67	25	0.44	47	0.88	53	4.99																										
5	5:30A	7071	2,072	561	3.9	29	0.29	56	0.65	54	3.12																										
6	5:40A	9143	1,091	303	4	15	0.3	30	0.66	32	3.52																										
7	5:40A	10234	2,130	595	4.07	32	0.33	59	0.57	58	3.91		117																								
8	5:40A	12320	1,708	353	2.97	17	0.22	33	0.46	36	2.53																										
9	6:00A	14045	1,508	554	5.29	29	0.42	47	0.75	49	3.9																										
10	5:55A	15533	2,138	607	4.62	34	0.35	53	0.59	67	3.78																										
11	5:40A	17591	1,184	450	5.46	19	0.34	6	0.12	33	3.34		96	46	7.28																						
12	6:00A	18275	2,033	787	5.42	33	0.35	0	0	61	3.59																										
13	6:00A	20908	1,912	410	3.09	19	0.21	0	0	26	1.63																										
14	5:50A	22820	1,151	564	7.05	23	0.44	0	0	53	5.62																										
15	5:15A	23871	2,159	765	5.1	32	0.32	0	0	67	3.17																										
16	6:00A	26130	1,624	507	4.49	25	0.35	29	0.43	48	3.54		118	56	7.12																						
17	5:25A	27754	2,15	612	4.1	29	0.29	56	0.52	49	2.68																										
18	5:30A	29624	1,073	375	5.08	18	0.37	33	0.74	33	3.69																										
19	6:00A	30977	1,987	563	4.11	23	0.33	54	0.66	53	3.23																										
20	5:50A	32964	1,97	495	3.61	23	0.32	54	0.66	47	2.86																										
21	6:10A	34934	1,644	493	4.31	23	0.34	49	0.71	44	3.21		117	47	7.31																						
22	6:05A	36578	1,988	515	3.73	20	0.33	63	0.64	51	3.68																										
23	5:25A	38566	2,001	530	3.83	20	0.33	54	0.55	50	3																										
24	6:05A	40507	1,172	360	4.42	21	0.39	37	0.76	44	4.5																										
25	6:30A	41739	2,16	548	3.65	23	0.38	53	0.58	45	2.49		95	46	7.28																						
26	6:00A	43659	1,165	472	5.82	23	0.43	47	0.96	42	4.32																										
27	6:00A	45196	1,981	310	2.25	15	0.18	32	0.39	30	1.82																										
28	5:50A	47177	0.99	410	5.96	22	0.48	47	1.14	46	3.57																										
29	6:00A	48167	1,719	365	3.06	20	0.25	40	0.56	39	2.72																										
30	5:30A	49586	1,787	603	4.56	20	0.37	60	0.81	57	3.82																										
31	6:45A	51673	1,867	367	2.83	19	0.22	39	0.5	29	1.86		119	46	7.25																						
TOT	0	865457	53,428	15506	125		10.18	1206	17.42	1420	103.6	0	0	800	0	0	0	336	167	0	0	5.07	6.458	173.7	26.63	0	0	0.44	0.61	16.66	75.29	1					
MAX	0	55040	2,253	787	7.05	34	0.48	60	1.14	67	5.07	0	0	138	0	0	0	54	7.36	0	0	0.67	0.322	7.79	1.42	0	0	0.05	0.066	0.92	3.3	2.93	0				
MIN	0	2253	0.99	303	2.25	15	0.18	0	0	26	1.63	0	0	95	0	0	0	46	7.12	0	0	0.01	0.246	7.11	0.95	0	0	0.01	0.013	0.68	1.4	0.22	0				
AVE	#DIV/0!	27917.968	1.7229387	500.8	4.354	25.1	0.229	38.9	0.562	45.81	3.343	average	average	114.3	average	average	average	48	7.259	average	average	0.22	0.281	7.551	1.156	average	average	0.019	0.027	0.811	2.429	1.806	average				

*Enter Final Reading Last Month _____

Pre & Post Filters: _____

Post Filter: _____

Pre Filter: _____

Post Filter: _____

POINT OF APPLICATION: _____

METER LOCATION: Main Pump Station

2. % Fluoride Solution Fed _____

3. % Solution Fed _____

4. % Solution Fed _____

CHLORINE
Type of Chlorine Used:

Chlorine Gas
 Calcium Hypochlorite
 Sodium Hypochlorite

Chlorine Test Kit Used: Hach DPD

FLUORIDATION
Type of Fluoride Used:

Hydrofluosilicic Acid, HF
 Sodium Fluoride
 Other

Type of Test Instrument Used: Hach SPADNS

This Agency is Authorized to require this information under Ill. Rev. Stat., 1976, Chapter 111 1/2, Section 1018. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continues, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the Farm Management Center.

I certify that the information in this report is complete and accurate to the best of my knowledge.

BDR 9110543 9-1-23

Reported by: (Signature) _____ Cert or Reg Number _____ Date _____

Phone: 815.223.0288 Date Monthly Copy by: (Signature) _____ (Signature) _____

DIVISION OF PUBLIC WATER SUPPLIES

Meter Read AM	RAW WATER			CHEMICALS APPLIED								FILTERS				CHEMICAL TESTS											REMARKS Use reverse side for additional remarks									
	Reading (1000 gal.)	Treated (1000 gal.)	Chlorine		Fluoride		NaMno4		Ortho Phosphate		Each day Indicate total previous backwash, if backwashed at mid-day, indicate hours previous/ hours following.	Wash Water Used Gal.	RAW					FINISHED																		
			Used lbs. or Gal.	Calc mg/l	Used lbs. or Gal.	Calc mg/l	Used lbs. or Gal.	Calc mg/l	Used lbs. or Gal.	Calc mg/l			pH	Alk. as CaCO3 mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	pH	Ortho Phosphate mg/l	Hard as CaCO3 mg/l	Fe mg/l	Mn mg/l	F mg/l	Cl res. F = free T = total												
			1	2	3	4	P	Tot	mg/l	mg/l			mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l											
a	b	c	d	e	f	g	h	i	j	k	l	m	n	o	p	q	r	s	t	u	v	w	x	y	z	aa	bb	cc	dd	ee	ff	gg	hh	ii		
1	6:00A	49020	1.814	416	3.3	25	0.3	57	0.75	38	2.51			25					7.28			0.09	0.4	7.63	1.36			0.02	0.06	0.88	1.54	1.31				
2	6:05A	1814	1.426	553	5.58	30	0.46	72	1.21	53	4.46														1.44			0.06	0.94	1.33	1.06					
3	5:40A	3240	1.379	487	5.08	25	0.39	64	1.11	49	4.28			44						24					1.3			0.11	0.96	1.24	0.88					
4	6:00A	4619	1.53	571	5.37	29	0.41	58	0.91	63	4.94			24	7.27					26			0.09	0.41	7.6	1.7		0.02	0.08	0.85	1.13	0.98				
5	6:00A	6149	2.067	631	4.35	27	0.28	57	0.65	67	3.85				7.27							0.09	0.42	7.6	1.69		0.02	0.05	0.87	1.78	1.49					
6	5:30A	6238	1.467	869	6.56	28	0.42	68	1.11	77	6.29			46						25			0.9	0.42	7.64	1.8		0.02	0.09	1.03	2.11	1.79				
7	6:00A	9703	1.764	611	4.98	31	0.38	64	0.87	68	4.62			24	7.3					24			0.1	0.41	7.73	1.7		0.02	0.06	0.83	2.52	2.11				
8	6:05A	11467	1.63	607	5.36	28	0.37	58	0.85	57	4.19				7.25							0.06	0.43	7.63	1.73		0.02	0.06	0.79	1.72	1.36					
9	7:40A	13097	1.723	432	3.6	21	0.27	41	0.57	53	3.69			45						25					1.74			0.1	1	1.71	1.44					
10	8:35A	14820	1.32	640	6.98	30	0.5	76	1.38	61	5.54														1.32			0.08	0.92	2.56	2.22					
11	5:30A	16140	1.466	554	5.44	24	0.36	47	0.77	50	4.09			46	7.37					24			0.04	0.44	7.68	1.84		0.02	0.15	0.96	2.33	1.99				
12	5:55A	17606	1.415	501	5.09	22	0.34	52	0.88	56	4.75				7.27							0.09	0.43	7.88	1.91		0.02	0.05	0.91	2.64	2.24					
13	5:50A	19021	1.639	503	4.42	20	0.27	50	0.73	68	4.97			47	7.31					25			0.11	0.43	7.74	1.79		0.02	0.07	0.94	2.89	2.56				
14	5:30A	20660	1.788	740	5.95	32	0.39	89	1.19	89	5.97				7.36							0.09	0.43	7.75	1.76		0.01	0.05	0.98	2.26	1.97					
15	6:15A	22448	1.845	595	4.64	23	0.27	58	0.75	56	3.64			49	7.26					25			0.1	0.43	7.7	1.84		0.02	0.11	0.79	1.87	1.58				
16	5:45A	24293	1.745	598	4.93	25	0.31	53	0.73	67	4.6														1.38			0.05	0.76	2.87	2.5					
17	5:50A	26038	1.456	587	5.8	25	0.37	64	1.05	68	5.6			43						25					1.89			0.07	0.91	2.61	2.24					
18	6:25A	27494	1.378	459	4.3	19	0.3	52	0.91	56	4.88				7.27							0.11	0.44	7.72	1.76		0.01	0.05	0.86	2.5	2.27					
19	6:30A	28870	1.38	526	5.48	20	0.32	51	0.89	60	5.21			43						25			0.11	0.42	7.82	1.77		0.03	0.09	0.82	1.78	1.44				
20	6:30A	30250	1.734	453	3.76	20	0.25	49	0.68	52	3.6				7.3							0.1	0.43	7.71	1.35		0.01	0.05	0.83	2.69	2.28					
21	6:45A	31984	1.451	590	5.85	26	0.39	62	1.02	7	0.58				7.36							0.3	0.42	7.66	1.97		0.03	0.12	0.94	1.93	1.74					
22	5:45A	33435	1.527	608	5.73	26	0.37	60	0.94	69	5.42			21						25			0.18	0.47	7.62	1.28		0.16	0.13	0.79	2.29	0.31				
23	7:15A	34962	1.416	478	4.86	21	0.32	49	0.83	57	4.83														1.83			0.06	0.92	1.09	0.83					
24	6:40A	36378	1.76	580	4.74	25	0.31	61	0.83	65	4.43			48						25					1.73			0.09	0.96	0.99	0.84					
25	6:25A	38138	1.706	463	3.9	20	0.26	49	0.69	50	3.51														1.95			0.05	0.87	1.74	1.48					
26	7:35A	39844	1.275	668	7.54	26	0.44	65	1.22	67	6.3			48						25					1.62			0.09	0.87	1.17	1.05					
27	5:40A	41119	1.526	507	4.78	21	0.3	53	0.83	59	4.64				7.26							0.16	0.44	7.56	1.91		0.03	0.04	0.84	1.79	1.5					
28	5:40A	42645	1.658	613	5.31	24	0.31	59	0.85	69	4.98			45						25			0.13	0.41	7.61	1.6		0.02	0.07	0.86	1.36	1.28				
29	6:10A	44303	1.433	539	5.41	23	0.34	55	0.92	66	5.52				7.17							0.15	0.42	7.44	1.85		0.01	0.03	0.93	2.3	1.75					
30	9:00A	45736	1.581	470	4.27	23	0.31	51	0.77	60	4.55			50						25					1.88			0.06	0.82	1.42	1.11					
31	10:00A	47317	1.443	393	3.91	13	0.19	37	0.61	51	4.23														1.77			0.02	0.64	1.92	1.54					
TOT.	0	790846	48.76	###	158		10.5	1781	27.5	1828	141	0	0	697	0	0	0	396	139	0	0	3	8.09	146	32.5	0	0	0.51	2.25	27.3	60	1				
MAX.	0	49020	2.087	740	7.54	32	0.5	89	1.38	89	6.3	0	0	50	0	0	0	25	7.49	0	0	0.9	0.47	7.82	1.97	0	0	0.16	0.15	1.03	2.69	2.56	0			
MIN.	0	1814	1.275	393	3.3	13	0.19	37	0.57	7	0.58	0	0	21	0	0	0	24	7.17	0	0	0.04	0.4	7.44	1.28	0	0	0.01	0.02	0.64	0.99	0.31	0			
AVE.	#DIV/0!	25511.16	1.572903	550	5.09	24.3	0.34	57.5	0.89	59	4.54	###	###	41	###	###	###	###	24.8	7.29	###	###	0.16	0.43	7.66	1.89	###	###	0.03	0.07	0.88	1.94	1.58	###	###	

*Enter Final Reading Last Month

POINT OF APPLICATION

METER LOCATION: Main Pump Station

2. % Fluoride Solution Fed

3. % Solution Fed

4. % Solution Fed

CHLORINE
Type of Chlorine Used:

X Chlorine Gas %
Calcium Hypochlorite %
Sodium Hypochlorite %

Chlorine Test Kit Used Hach DPD

FLUORIDATION
Type of Fluoride Used:

X Hydrofluosilicic Acid, %F %
Sodium Fluoride %
Other %

Type of Test Instrument Used: Hach SPADNS

This Agency is Authorized to require this information under Ill. Rev. Stat., 1979, Chapter 111 1/2, Section 1019. Disclosure of this information is required. Failure to do so may result in a civil penalty up to \$10,000.00 and an additional civil penalty up to \$1,000.00 for each day the failure continues, a fine up to \$1,000.00 and imprisonment up to one year. This form has been approved by the Forms Management Center.

I certify that the information in this report is complete and accurate to the best of my knowledge

Reported by: (Signature) Date Monthly Done by: I POC LABS Bacterials Sent

